



INSTITUT PRO TESTOVÁNÍ A CERTIFIKACI, a. s.
DIVIZE CSI – CENTRUM STAVEBNÍHO INŽENÝRSTVÍ
 Workplace in Zlín, K Cihelně 304, 764 32 Zlín - Louky



issues to

Applicant: **FIRMA PRODUKCYJNO-USŁUGOWO-HANDLOWA "RADAKS" S.C.**
RAFAŁ JERUZAL, ADAM PUDELSKI
ALEJA RÓŻANA 52, 76-200 SŁUPSK, Poland

CERTIFICATE

Of the product characteristic

No. CV - 20 - 047Z

Product: **Vent flap on the plastic window system MD**

Manufacturer: See applicant

Description:	Single leaf window; dimension frame (1230 x 1480) mm		
Frames thick // glazing	frame 62 mm, sash 96 mm // triple unit glass		
Seals between sash and frame	middle, outside and inside, system MD		
Hardware	Maco		
Description venting	Option no. 1	Option no. 2	Option no. 3
-outside: ventilation gasket	2x 150 mm	2x 150 mm	2x 250 mm
-inside	2x flap (2x125) mm	3x flap	4x flap

This Certificate approves conformity of the above mentioned properties of the product values declared by the manufacturer:

Tested characteristic	Testing metod	Conforms to	Results
Air permeability	EN 1026	EN 12207	klasa 2
Water tightness	EN 1027	EN 12208	klasa E750
Flow rate	Option no. 1	Option no. 2	Option no. 3
Press difference [Pa]	2 4 8 10	2 4 8 10	2 4 8 10
Air flow [m³/hod]	2,5 3,8 5,0 5,2	3,0 3,7 5,6 5,5	4,4 5,5 8,2 9,8

Background documents: - Test report No. 306/2015; 2.9.2015, AZL No. 1007.1, CSI a.s. Zlín

The Certificate applies only for product which its specification is given in the Test Report in detail. The Certificate verifies the above mentioned product properties, however, it does not represent nor substitute the certification in accordance with Technical Requirements for Products.



Issue date: 30.05.2022
Valid till: 30.05.2025

Ing. Jindřich Mrlik
 Ing. Jindřich Mrlik